



CERTIFICATE OF APPROVAL

No CF 719

This is to certify that, in accordance with
 TS00 General Requirements for Certification of Fire Protection Products
 The undermentioned products of

EUROSPEC ARCHITECTURAL HARDWARE LIMITED

Stancliffe Street, Mill Hill, Blackburn, Lancashire, BB2 2QR
Tel: 01254 274100 Fax: 01254 274111

Have been assessed against the requirements of the Technical Schedule(s)
 denoted below and are approved for use subject to the conditions
 appended hereto:

CERTIFIED PRODUCT

**Panic And Emergency Exit
 Devices**

TECHNICAL SCHEDULE

**TS 26 - The Contribution of
 Panic Exit Devices, Operated
 by a Horizontal Bar, to the
 Performance of Fire Resisting
 Door Assemblies**
**TS 31 - The Contribution of
 Emergency Exit Devices,
 Operated by a Lever Handle or
 Push Pad, to the Performance
 of Fire Resisting Door
 Assemblies**

Signed and sealed for and on behalf of CERTIFIRE



Sir Ken Knight
 Chairman
WCL Impartiality Committee



Paul Duggan
 Certification Manager
Warrington Certification Ltd



Issued: 17th May 2010
 Reissued: 5th November 2015
 Valid to: 31st August 2020

Page 1 of 5



CERTIFICATE No CF 719

EUROSPEC ARCHITECTURAL HARDWARE LIMITED

Eurospec Panic And Emergency Exit Devices

1. This approval relates to the push bar push bar panic exit device range XDB5760, XDL5760, XDD5760, XSL5760, XSL5760H, XSL5760V, XSD5760, XPL5000H, XPL5000V, XPR5001 and XIA5003, XSA5003, XSA5012 accessories. The touch bar panic exit device range XIT5120, XIT5120H, XIT5120V, XID5120V, XIT5760, XIT5760H, XIT5760V, XID5760V, XPL5000H, XPL5000V, XIA5001H, XIA5001V, XPR5000 and XIA5003, XSA5003, XIA5012 accessories. The XSA5002 & XIA5002 emergency escape devices with XIA5003 and XSA5003 accessories. The DLS7260ESC escape lock.
2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section 2 of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.'
3. This approval relates to the use of the above mentioned panic and emergency exit devices and components with the following door assemblies:

Latched and unlatched, door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (Codes TT, ITT and ITC).

Latched and unlatched door assemblies (intumescent sealed or non-intumescent sealed) consisting of metallic faced and edged leaves with cellulosic or mineral cores in steel frames, having a fire resistance of up to 240 minutes (IMM and MM).
4. The exit devices are approved on the basis of:
 - i) Initial type testing to EN 1125: 2008/EN 179: 2008 for mechanical properties
 - ii) Initial type testing to EN 1634-1 for the fire resistance performance of doorsets
 - iii) An appraisal against TS26 and TS31
 - iv) Ongoing audit testing in accordance with EN 1125/EN179
 - v) Certification of quality management system to ISO 9001: 2008.
 - vi) Inspection and surveillance of factory production control
5. This approval is applicable only to the specified exit devices and relevant accessories when used with door assemblies of proven fire resistance (as defined by EN 1634-1 and BS 476: Part 22: 1987). Failure to install the device and accessories in the appropriate manner will invalidate this certificate of approval.
6. The approval relates to on going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

CERTIFICATE No CF 719
EUROSPEC ARCHITECTURAL
HARDWARE LIMITED

Eurospec Panic And Emergency Exit Devices

Approval Matrix for push bar panic exit device range XDB5760, XDL5760, XDD5760, XSL5760, XSL5760H, XSL5760V, XSD5760, XPL5000H, XPL5000V, XPR5001 and XIA5003, XSA5003, XSA5012 accessories. The touch bar panic exit device range XIT5120, XIT5120H, XIT5120V, XID5120V, XIT5760, XIT5760H, XIT5760V, XID5760V, XPL5000H, XPL5000V, XIA5001H, XIA5001V, XPR5000 and XIA5003, XSA5003, XIA5012 accessories. The XSA5002 & XIA5002 emergency escape devices with XIA5003 and XSA5003 accessories. The DLS7260ESC escape lock.

Class	Approved Door Type					
	IMM	MM	TT	ITT	ITM	ITC
FD20	✓	✓	✓	✓	✓	✓
FD30	✓	✓	x	✓	✓	✓
FD60	✓	✓	x	✓	✓	✓
FD120	✓	✓	x	✓	✓	✓
FD240	✓	✓	x	x	x	x
E 20	✓	✓	✓	✓	✓	✓
EI 20	✓	✓	✓	✓	✓	✓
E 30	✓	✓	x	✓	✓	✓
EI 30	✓	✓	x	✓	✓	✓
E 60	✓	✓	x	✓	✓	✓
EI 60	✓	✓	x	✓	✓	✓
E 90	✓	✓	x	✓	✓	✓
EI 90	✓	✓	x	✓	✓	✓
E 120	✓	✓	x	✓	✓	✓
EI 120	✓	✓	x	✓	✓	✓
E 240	✓	✓	x	x	x	x
EI 240	✓	✓	x	x	x	x

See CERTIFIRE Technical Schedules for designation of doorset types i.e. IMM etc.



CERTIFICATE No CF 719
EUROSPEC ARCHITECTURAL
HARDWARE LIMITED

Eurospec Panic Exit Devices

Classification codes

The approval provides the following classifications:

XDB5760, XDL5760, XDD5760, XSL5760, XSL5760H, XSL5760V, XSD5760, XPL5000H, XPL5000V, XPR5001 Push bar panic exit device range and XIA5003, XSA5003, XSA5012 accessories

3	7	6	B	1	4	2	2	A	A
---	---	---	---	---	---	---	---	---	---

XIT5120, XIT5120H, XIT5120V, XID5120V, XIT5760, XIT5760H, XIT5760V, XID5760V, XPL5000H, XPL5000V, XIA5001H, XIA5001V, XPR5000 Touch bar panic exit device range and XIA5003, XSA5003, XIA5012 accessories

3	7	6	B	1	4	2	2	B	A
---	---	---	---	---	---	---	---	---	---





**CERTIFICATE No CF 719
EUROSPEC ARCHITECTURAL
HARDWARE LIMITED**

Eurospec Emergency Exit Devices

Classification codes

The approval provides the following classifications:

XSA5002 Emergency Exit Device used with XIA5003, XSA5003 accessories

3	7	6	B	1	4	2	2	B	A
----------	----------	----------	----------	----------	----------	----------	----------	----------	----------

XIA5002 Emergency Exit Device used with XIA5003, XSA5003 accessories

3	7	6	B	1	4	2	2	B	B
----------	----------	----------	----------	----------	----------	----------	----------	----------	----------

DLS7260ESC Escape Lock

3	7	6	B	1	4	4	2	A	B/D
----------	----------	----------	----------	----------	----------	----------	----------	----------	------------

Further Information

Further information regarding the details contained in this data sheet may be obtained from Eurospec Architectural Hardware Limited (Tel: 01254 274100).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

